



VOC/PRODUCT DATA SHEET

Date:	July 16, 2018
Vendor Name:	Flexmaster Canada Limited
Vendor Address:	20 East Pearce Street, Richmond Hill, ON L4B 1B7
Contact:	
Telephone:	905-731-9411
Product Name/Number:	Ductbond Duct Sealant
VOC (weight %)*:	1.0 %
VOC (grams/liter as supplied):	24 g/l
VOC Emissions TVOC Range**	14 µg/m ³ Classroom – 33 µg/m ³ Private Office
Solids (weight %):	69 %
Product Weight per Gallon (ASTM D-792):	11.7 lbs/gal

Ductbond Duct Sealant meets the VOC Emissions and Content requirements to contribute to LEED v4 EQ Credit: Low Emitting Materials – Adhesives and Sealants

Requirements:

VOC emissions: Building products must be tested and determined compliant in accordance with California Department of Public Health (CDPH) Standard Method v1.1–2010 /1.2

VOC Content: Meet requirements of SCAQMD Rule 1168

Sealants:

Architectural: 250 g/l, less water and exempts

Other: 420 g/l, less water and exempts



CDPH Standard Method Version 1.2
LEED v4: TVOC <0.5 mg/m³ (500 µg/m³)

*The VOC content information presented here is calculated based on the theoretical VOC contribution of each ingredient in each formulation. The VOC information for each ingredient is either measured using EPA Method 24 (40 CFR 60 Appendix A), or per composition data as reported to us by the supplier (40 CFR 63.827(b)).

**TVOC determined by CDPH v1.2 for this product or chemical family.

"Globally specified, proven and preferred"