

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 2020-0420-MH46971  
**Report Reference** MH46971-20140324  
**Issue Date** 2020-APRIL-20

**Issued to:** FLEXMASTER CANADA LTD  
UNIT 1  
20 E PEARCE ST  
RICHMOND HILL  
ON L4B 1B7 CANADA


**This is to certify that representative samples of** AIR CONNECTORS  
See Addendum for Additional Information.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 181, Factory Made Air Ducts and Air Connectors.  
CAN/ULC-S110, Standard Methods of Tests for Air Ducts.  
CAN/ULC-S102, Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies.

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 2020-0420-MH46971  
**Report Reference** MH46971-20140324  
**Issue Date** 2020-APRIL-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## **Addendum -**

Air Connectors, Class 1, flexible. Designation "Medical Grade Acoustic Air Connector"

Air connector consists of a spirally wound, corrugated aluminum tube, with poly-sleeve, insulation and vapor barrier.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

